

COFFS HARBOUR LABORATORY

Environmental Analysis Page 1 of 1



STUARTS POINT CONVENTION CENTRE
GLENNHOUSSEN LOGE
250 GRASSY HEAD ROAD
STUARTS POINT NSW 2441

BATCH NUMBER: 17/2441
No. of SAMPLES: 1
DATE COLLECTED: 15/11/17
DATE RECEIVED: 15/11/17
TIME RECEIVED: 10:22
DATE TESTING COMMENCED:
15/11/17

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
17/2441/1	STUARTS POINT CONVENTION CENTRE EFFLUENT

ANALYSIS	UNITS	17/2441/1				METHOD NO
pH	pH unit	7.3				APHA 4500-H+ B
Total Suspended Solids	mg/L	31				APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	12				APHA 5210 B
Faecal Coliforms	cfu/100mL	235				APHA 9222 D
Total Nitrogen	mg/L	1.95				EL30F
Total Phosphorus	mg/L	0.18				EL18F

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 22nd Edition, 2012, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Report Date: 20/11/17



Accredited for compliance with ISO/IEC 17025.
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

Approved:

B J Wadleigh
Laboratory Manager

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and international standards.