

COFFS HARBOUR LABORATORY

Environmental Analysis

Page 1 of 1



STUARTS POINT CONVENTION CENTRE
GLENN HOUSSEN LOGE
250 GRASSY HEAD ROAD
STUARTS POINT NSW 2441

BATCH NUMBER: 20/1897
No. of SAMPLES: 1
DATE COLLECTED: 20/08/20
DATE RECEIVED: 20/08/20
TIME RECEIVED: 09:57
DATE TESTING COMMENCED:
20/08/20

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
20/1897/1	STUARTS POINT CONVENTION CENTRE EFFLUENT

ANALYSIS	UNITS	20/1897/1				METHOD NO
pH	pH unit	6.7				APHA 4500-H+ B
Total Suspended Solids	mg/L	11				APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	<4				APHA 5210 B
Faecal Coliforms	cfu/100mL	10				ELM 3
Total Nitrogen	mg/L	0.62				EL30F
Total Phosphorus	mg/L	0.39				EL18F

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 23rd Edition, 2017, APHA. Raw data sheets stating analysis dates are available upon request.


Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Measurement Uncertainty is available upon request.

Report Date: 26/08/20

Approved:


B J Wadleigh
Laboratory Manager



Accredited for compliance with ISO/IEC 17025 - Testing
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.